



Representative Image

Catalog No. TQL100R

Description: ENCLOSURE NEMA 3R 100A

UPC No 783164021417

Home > Circuit Breakers > Circuit Breaker Enclosures

GE's circuit breaker enclosures are UL Listed, CSA Certified and are suitable for use as service equipment (except as noted). The short circuit rating of the enclosure/circuit breaker combination is equal to the short circuit rating of the installed circuit breaker. Frame notes and/or restrictions THQL, TXQL, THQL-GF (1, 2, 3 Pole) Enclosure notes and/or limitation Enclosure cannot accommodate a 3-pole breaker with accessory. ACCESSORIES Neutral Kit (non-GF applications) included 100R Amps 100 A

Descriptors

Category	Circuit Breaker Enclosures
GO Schedule	B3

Specifications

Enclosure Type	NEMA Type 3R
Mounting	Surface
Frame Type	Q-Line
Amperage	100 A
Material	Steel
GSA Compliance	Yes

Classifications

UL/CUL Listing	CSA UL
----------------	-----------

Dimensions

Height	17.00 in
Depth	5.00 in
Width	6.88 in
Weight	10.5 lb

